

Construction Change Directive No. 6

To: DoNo Hartford LLC
Date: 05/31/2016
Contract For: General Construction
Project No.: 14104.00
Contract Date: 03/23/2015
Project: DoNo Hartford Ballpark

Distribution: Jonathan Cole- Pendulum
Kevin Greene - IFG

You are hereby directed to make the following change(s) in this Contract:

Per previously discussed building official site inspection comments;

SK-BF – Rerouting the boiler flue out of the plenum ceiling per building official's comments

SK-ST1 – Shifting run in stair 1 to avoid built door interference

SK-ST3 – Premium knuckle seat adjustment and accelerator stair detail

ASK-100 – Main Concourse accelerator stair detail to remove stair winder

SK-GT1 – Added stairwell egress safety gate detail

SK-GT2 – Added stairwell egress safety gate plans

SK- R1 – Railing detail – area F concourse

SK-RL – Premium level suite railings extended per building official comments

SK-R2 – Guard railing added at upper exhaust fans per building official comments

SKP-16 – Heat trace added to WC piping in unheated space

EP100.4 – Power added to heat trace to WC piping in unheated space

EP101.3 – Power added at main concourse per building official comments

EP103.1 – lighting added at rooftop MAU per building official request

H102.1 – Grease exhaust duct relocated per building official comments

H102.2 – Grease exhaust duct relocated per building official comments

H103.1 – MAU venting relocated per building official comments

H400 – Revised hot water schematic flow diagram per building official comments

Per review of exit signage by Fire Marshall;

EL100.2 – Added EXIT sign

EL100.3 – Added EXIT sign

EL100.4 – Added EXIT sign

EL101.1– Added EXIT sign

EL101.2 – Added EXIT sign

SLAM

CT | GA | MA | NY

80 Glastonbury Blvd
Glastonbury, CT 06033

860.657.8077

www.slamcoll.com

- EL101.3**– Added EXIT sign
- EL101.4** – Added EXIT sign
- EL101.6** – Added EXIT sign & emergency lighting
- EL102.1** – Added EXIT sign
- EL102.2** – Added EXIT sign
- EL102.3** – Added EXIT sign
- EL102.4** - Added EXIT sign
- EL102.6** – Added EXIT sign
- EL102.7** – Added EXIT sign

Proposed Adjustments

1. The Proposed basis of adjustment to the Contract Sum or Guaranteed Maximum Price is:
 - Lump Sum increase / decrease of \$
 - Unit Price of \$ per
 - as provided in Subparagraph 7.3.6 of AIA Document A201, 2007 edition.
 - as follows: Submit itemized pricing.
2. The Contract Time is proposed to be adjusted / remain unchanged. The proposed adjustment, if any, is an increase / a decrease of days.

When signed by the Owner and Architect and received by the Contractor, the document becomes effective IMMEDIATELY as a Construction Change Directive (CCD), and the Contractor shall proceed with the change described above.

Signature by the Contractor indicates the Contractor's agreement with the proposed adjustments in the Contract Sum and Construction Contract Time set forth in this Change Directive.

SLAM Collaborative
Architect

The City of Hartford
Owner

Centerplan Construction Co.
Contractor

Chris Sziabowski
By

By

By

May 31, 2016
Date

Date

Date